

Boiler-Log (24).xls																	
1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1	02.02.2018	Oxygen	T.Boiler	T.Exhaust	Photocell	S.Boiler	S.Burner P	S.Burner D	P-Flap	S-Flap	Fan-Exhaust	Fan-Burner	Pump	UpperSensor	MiddleSensor	LowerSensor	OutsideSensor
1096	19:50:00	19.5	38.7	36.1		0 STARTING	READY	IGNITION	100	2	100	40 OFF		55.1	34.4	33.2	-300 OFF
1097	19:50:10	19.2	38.7	37.5		0 STARTING	READY	IGNITION	100	2	100	40 OFF		55	34.4	33.2	-300 OFF
1098	19:50:20	19.5	38.7		39	0 STARTING	READY	IGNITION	100	2	100	40 OFF		55	34.4	33.2	-300 OFF
1099	19:50:30	1.1		0	0	-300 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1100	19:50:40	1.1		0	0	-300 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1101	19:50:50	1.1		0	0	-300 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1102	19:51:00	1.1		0	0	0 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1103	19:51:10	1.1		0	0	0 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1104	19:51:20	BOILER OFF															
1105	19:51:40	1.1		0	0	-300 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1106	19:51:50	1.1		0	0	-300 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1107	19:52:00	1.1		0	0	-300 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1108	19:52:10	1.1		0	0	0 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1109	19:52:20	1.1		0	0	0 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1110	19:52:30	1.1		0	0	0 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1111	19:52:40	1.1		0	0	0 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1112	19:52:50	1.1		0	0	0 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON
1113	19:53:00	1.1		0	0	0 STARTING	READY	ERROR	0	25	0	0 OFF		-300	-300	-300	-300 ON